

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-1335:100

Page 1 of 1

CATEGORY: Power Units

LISTEE: Altronix, 140 - 58th Street, Bldg. A-3W, Brooklyn, NY 11220
Contract: *Alan Forman (718) 567-8181 Fax (718) 567-9056

DESIGN: Models AL300ULX, AL300ULM, AL400UL, AL400ULX, AL400ULM, AL400UL3X , AL600UL3X, AL1024ULM and AL1024ULX power supply units. Model AL400ULX is identical to Model AL400UL except for a larger enclosure. Models AL400ULM is basically an AL400ULX with a MOM5 multi-output power module also typical of Models AL1024ULM and AL1024ULX respectively. Models AL300ULX and AL300ULM are designed to charge sealed lead acid type rechargeable batteries. Models AL400UL3X and AL600UL3X employ the triple output module ALX3B. Model Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 VAC input, 12 or 24 VDC output

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the standby batteries must provide 24 hours standby power during power loss.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units to provide power for door holders, door strikes or similar devices.

NOTE: Not suitable for fire alarm indicating devices.

*Rev. 06-14-2003IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**